

SYSTEM WATER TEST

A simple test to determine the quality of central heating system water and the necessary treatment required to:

- Help prevent boiler breakdown
- Maintain maximum system efficiency
- Extend the life of the boiler


How to use

The Fernox Protector Test Kit is designed to give rapid on-site analysis of the concentration of Fernox Protectors in central heating systems.

The optimum figure quoted in the instructions is when the system is dosed at the recommended strength. However, higher values are not detrimental and are preferable to under-dosing.


Step 1

Fill the tube with central heating system water up to the 50 ml line.



Step 2

Look down the tube and focus on the black and yellow Target.



Step 3

Depending on the cleanliness of the water there are four water treatment options:

1. If the target is clearly visible and the system has been inhibited (boiler displaying a water treatment label) Action: None required
2. The Target is visible but blurred, indicating contaminants are present in the system water. Action: Fit a Fernox TF1 Filter and dose with Fernox Filter Fluid+ Protector
3. The Target is visible but blurred, indicating contaminants are present in the system water. Action: Fit a Fernox TF1 Filter and dose with Fernox Filter Fluid+ Protector
4. The Target is not visible indicating a heavily sludged and dirty system. Action: Clean the system with Fernox F3 /F5 Cleaner, fit a Fernox TF1 Filter and dose with Fernox Filter Fluid+ Protector



Fernox System Water Test

Size: **N/A**
Code: **62254**